CIVIL EXPERTS
ISO 9001:2008
CONSULTANTS & TESTING CENTER

174, Sri Ranga Complex
Amrutha Nagar Main Road
New Bank Colony, Konanakunte
Bangalore - 560 062.
Mobile : +91 97429 59595
Tele/Fax : 080-2632 2565
E-mail : civilexpertsltd@gmail.com
URL : www.civilexperts.in

NABL ACCREDITED AS PER ISO/IEC 17025:2005

Job No.: CECTC-RV-W N-16-2015-16 Date : 02.01.2015

TEST REPORT ON COARSE AGGREGATES
IS 383-1970 (RA- 2002)

Client : **Executive Engineer,** Rajarajeshwari Nagara Division, BBMP, Bangalore.

Agency : **Sri.Raghavendra,** contractor, Bangalore.

Name of Work : Providing RCC drain and Improvements to footpath at 1st A cross Sharadamba Nagara in Ward no.16

Reference : EE/RRND/W.O No/79/2014-15 Dated: 07.08.2014

Date of Testing : 02.01.2015

Material : 40mm Aggregates

Total wt. of aggregates in gms = **15000**

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Spec.Limits
80	0	0	0	100	100
40	388	2.59	2.59	97.41	95-100
20	8547	56.98	59.57	40.43	30-70
10	3519	23.46	83.03	16.97	10-35
4.75	2145	14.30	97.33	2.67	0-5

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 15 days from the date of testing .

'or Civil Expert

Authorised Signature